



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION #

2681

050464-2

326567

1. WELL CONTRACTOR:

STEVE PETTY

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 4/19/2006

TIME COMPLETED 4:00 AM PM

3. WELL LOCATION:

CITY: DRILLED DEEPER COUNTY: WATAUGA

APPLE ORCHARD LANE OFF HARDIN RD. OFF 421

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other (check appropriate box)

LATITUDE 3

LONGITUDE

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 405

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 80 FT. (Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 30 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount

g. WATER ZONES (depth):

From OLD To WELL From 378 To 378

From To From To

From To From To

6. CASING:

Depth Diameter Weight Material

From 0 To Ft.

From 0 To 0 Ft.

From To Ft.

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From To Ft.

From To Ft.

8. SCREEN:

Depth Diameter Slot Size Material

From To Ft. in. in.

From To Ft. in. in.

From To Ft. in. in.

9. SAND/GRAVEL PACK:

Depth Size Material

From To Ft.

From To Ft.

From To Ft.

10. DRILLING LOG

From To Formation Description

0 305 OLD WELL

0 0 DRILLED DEEPER

305 378 SHALE

378 405 GRANITE

11. REMARKS:

2 GPM OLD - WELL 28 GPM 378 - 378

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

SIGNATURE OF CERTIFIED WELL CONTRACTOR STEVE PETTY DATE 5-11-06

PRINTED NAME OF PERSON CONSTRUCTING THE WELL