WSRO

329349

NON RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

41051336 WELL CONTRACTOR CERTIFICATION # 2220 Well #17

1. WELL CONTRACTOR:
Gary H. Sherrill
Well Contractor (Individual) Name
McCall Bros. Inc.
Well Contractor Company Name
STREET ADDRESS P.O. Box 668710
Charlotte NC. 28216
City or Town State Zip Code
704-399 1506
Area code- Phone number

2. WELL INFORMATION:
SITE WELL ID #(if applicable) NA
STATE WELL PERMIT#(if applicable) NA
DWQ or OTHER PERMIT #(if applicable) NA
WELL USE (Check Applicable Box) Monitoring ☐ Municipal/Public ☑
Industrial/Commercial ☐ Agricultural ☐ Recovery ☐ Injection ☐
Irrigation ☐ Other ☐ (list use)
DATE DRILLED 6-7-06
TIME COMPLETED 3:30 AM ☐ PM ☑

3. WELL LOCATION:
CITY: Ferguson COUNTY: ~~Wilkes~~ WATAUGA
Gwn Corp / Laurel Creek
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)
TOPOGRAPHIC / LAND SETTING:
☐ Slope ☑ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)
LATITUDE 36° 10.587'
LONGITUDE 081° 32.101'
May be in degrees, minutes, seconds or in a decimal format
Latitude/longitude source: ☑ GPS ☐ Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:
a. TOTAL DEPTH: 905
b. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☑
c. WATER LEVEL Below Top of Casing: NA FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS Removed FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.
e. YIELD (gpm): 0 METHOD OF TEST Air lift
f. DISINFECTION: Type HTH Amount 2 oz.
g. WATER ZONES (depth): NA
From ____ To ____ From ____ To ____
From ____ To ____ From ____ To ____
From ____ To ____ From ____ To ____

6. CASING: Removed

From	To	Depth Ft.	Diameter	Thickness/ Weight	Material

7. GROUT:

From	To	Depth Ft.	Material	Method
0	70		Concrete	Gravity Flow

8. SCREEN: NA

From	To	Depth Ft.	Diameter in.	Slot Size in.	Material

9. SAND/GRAVEL PACK:

From	To	Depth Ft.	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	3	top soil
3	5	boulders
5	19	brown clay
19	39	sand stone
39	63	gravite
63	905	granitic gneiss

11. REMARKS:
Dry hole, No fractures
63-66 casing pulled out

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Gary H. Sherrill 6-7-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Gary H. Sherrill
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

RECEIVED JUL 19 2006 DIV. OF WATER QUALITY

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.