



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WSRo

329371

WELL CONTRACTOR CERTIFICATION # 2686

060239

1. WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**
BOONE NC 28607

City or Town State Zip Code
(**828**) **264-2651**
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **5/17/2006**

TIME COMPLETED **11:00** AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

LOT # 10 OFF ODES WILSON RD. OFF SILVERST

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 **36.18031**
LONGITUDE 081.46379

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 120

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: 10 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 25 METHOD OF TEST Air

f. DISINFECTION: Type **HTH** Amount **23**

g. WATER ZONES (depth):
From 55 To 56 From _____ To _____
From _____ To _____ From _____ To _____
From _____ To _____ From _____ To _____

6. CASING: Thickness/
Depth Diameter Weight Material
From 0 To 49 Ft. **6 1/4** **.188** **GALV**
From 0 To 0 Ft. _____ _____
From _____ To _____ Ft. _____ _____

7. GROUT: Depth Material Method
From 0 To 52 Ft. **BENTONIT** **Gravity Flow**
From _____ To _____ Ft. _____ _____
From _____ To _____ Ft. _____ _____

8. SCREEN: Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Depth Size Material
From _____ To _____ Ft. _____ _____
From _____ To _____ Ft. _____ _____
From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From	To	Formation Description
0	30	MUD BOULDERS
30	46	MUD GRAVEL
46	55	GRANITE
55	58	SHALE
58	120	GRANITE

RD

11. REMARKS:

25 GPM 55 - 58 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 6-7-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
LESLIE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

DIV. OF WATER QUALITY
JUL 19 2006