WS RW

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

329417

WELL CONTRACTOR CERTIFICATION # 2687

060261

1. WELL CONTRACTOR:

STEVE REECE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828 - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐ X
DATE DRILLED 6/6/2006
TIME COMPLETED _____ AM ☐ PM ☐X

3. WELL LOCATION:

CITY: BOONE COUNTY WATAUGA

LOT #4 WINDING CRK LN OFF GEORGE HAYES
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 3 36.10766
LONGITUDE 081.38341
May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☐ GPS ☐ Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 345

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☐X

c. **WATER LEVEL** Below Top of Casing: 20 FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. **YIELD (gpm):** 6.5 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount** 67

g. **WATER ZONES** (depth):
From 226 To 229 From _____ To _____
From _____ To _____ From _____ To _____
From _____ To _____ From _____ To _____

6. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From	0 To	21 Ft.	6 1/4	188	GALV
From	0 To	0 Ft.			
From	To	Ft.			

7. GROUT:

	Depth		Material	Method
From	0 To	20 Ft.	Cement	Gravity Flow
From	To	Ft.		
From	To	Ft.		

8. SCREEN:

	Depth		Diameter	Slot Size	Material
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From	To	Ft.		
From	To	Ft.		
From	To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	15	DIRT
15	226	GRANITE
226	229	QUARTZ
229	345	GRANITE

11. REMARKS:

6.5 GPM 226 - 229 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 7-11-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

RECEIVED DIV. OF WATER QUALITY JUL 19 2006

(129

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05