



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

330315

WELL CONTRACTOR CERTIFICATION # **2686**

060256

1. WELL CONTRACTOR:

LESLIE REECE
 Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.
 Well Contractor Company Name
 STREET ADDRESS **P. O. BOX 308**
BOONE NC 28607
 City or Town State Zip Code
 (**828**) - **284-2651**
 Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
 STATE WELL PERMIT #(if applicable) _____
 DWQ or OTHER PERMIT #(if applicable) _____
 WELL USE (Check Applicable Box): Residential Water Supply
 DATE DRILLED **6/7/2006**
 TIME COMPLETED **10:30** AM XPM

3. WELL LOCATION:

CITY: **BOONE** COUNTY **WATAUGA**
LOT #2 OFF APPLE CREEK OFF RUSS CORNET
 (Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
 (check appropriate box)

LATITUDE 3 36.11524
 LONGITUDE 081.41620

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **400**
 b. DOES WELL REPLACE EXISTING WELL? YES NO
 c. WATER LEVEL Below Top of Casing: **20** FT.
 (Use "+" if Above Top of Casing)
 d. TOP OF CASING IS **1** FT. Above Land Surface*
 * Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
 e. YIELD (gpm): **2** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **75**

g. WATER ZONES (depth):
 From **197** To **198** From **364** To **365**
 From _____ To _____ From _____ To _____
 From _____ To _____ From _____ To _____

6. CASING: Thickness/
 Depth Diameter Weight Material
 From **0** To **140** Ft. **6 1/8** **.350** **PVC**
 From **0** To **0** Ft. _____ _____
 From _____ To _____ Ft. _____ _____

7. GROUT: Depth Material Method
 From **0** To **20** Ft. **Cement** **Gravity Flow**
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

8. SCREEN: Depth Diameter Slot Size Material
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Depth Size Material
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From	To	Formation Description
0	136	DIRT/SAND
136	197	GRANITE
197	198	QUARTZ
198	364	GRANITE
364	365	QUARTZ
365	400	GRANITE

11. REMARKS:

0.5 GPM 197 - 198 1.5 GPM 364 - 365
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece **7-21-06**
 SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
LESLIE REECE
 PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.