330817

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2686 060198

1. WELL CONTRACTOR:

LESLIE REECE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐ X
DATE DRILLED 6/16/2006
TIME COMPLETED 3:00 AM ☐ PM ☐X

3. WELL LOCATION:

CITY: BLOWING ROCK COUNTY WATAUGA

LOT # 8 OFF OLD STEEL HOUSE CRK RD. OFF B
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 3 38.07520
LONGITUDE 081.38402

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☐ X GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 500

b. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☐X

c. WATER LEVEL Below Top of Casing: 30 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 1.33 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 94

g. WATER ZONES (depth):

From	To	From	To
81	82	420	421

6. CASING:

Depth From	To	Ft.	Diameter	Thickness/ Weight	Material
0	58		6 1/8	.350	PVC
0	0				

7. GROUT:

Depth From	To	Ft.	Material	Method
0	20		Cement	Gravity Flow

8. SCREEN:

Depth From	To	Ft.	Diameter in.	Slot Size in.	Material

9. SAND/GRAVEL PACK:

Depth From	To	Ft.	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	55	DIRT
55	81	GRANITE
81	82	QUARTZ
82	420	GRANITE
420	421	QUARTZ
421	500	GRANITE

11. REMARKS:

0.33 GPM 81 - 82 1 GPM 420 - 421
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 7-21-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

RECEIVED DIV. OF WATER QUALITY 2006

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05