



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

330818

WELL CONTRACTOR CERTIFICATION # 2878

060341

1. WELL CONTRACTOR:

STEVE PRICE
 Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.
 Well Contractor Company Name
 STREET ADDRESS P. O. BOX 308
BOONE NC 28607
 City or Town State Zip Code
 (828) - 264-2651
 Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
 STATE WELL PERMIT #(if applicable) _____
 DWQ or OTHER PERMIT #(if applicable) _____
 WELL USE (Check Applicable Box): Residential Water Supply X
 DATE DRILLED 8/27/2006
 TIME COMPLETED 2:00 AM PM X

3. WELL LOCATION:

CITY: BOONE COUNTY: WATAUGA
GEORGES GAP RD. OFF OLD 421 OFF 321 OFF 4
 (Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
 (check appropriate box)

LATITUDE 3 38.16519
 LONGITUDE 081.48260

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 1005
 b. DOES WELL REPLACE EXISTING WELL? YES NO X
 c. WATER LEVEL Below Top of Casing: 300 FT.
 (Use "+" if Above Top of Casing)
 d. TOP OF CASING IS 1 FT. Above Land Surface*
 *Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
 e. YIELD (gpm): 4 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 136

g. WATER ZONES (depth):
 From 970 To 972 From _____ To _____
 From _____ To _____ From _____ To _____
 From _____ To _____ From _____ To _____

6. CASING: Thickness/
 Depth Diameter Weight Material
 From 0 To 28 Ft. 8 1/4 188 GALV
 From 0 To 0 Ft. _____
 From _____ To _____ Ft. _____

7. GROUT: Depth Material Method
 From 0 To 20 Ft. Cement Gravity Flow
 From _____ To _____ Ft. _____
 From _____ To _____ Ft. _____

8. SCREEN: Depth Diameter Slot Size Material
 From _____ To _____ Ft. _____ in. _____ in.
 From _____ To _____ Ft. _____ in. _____ in.
 From _____ To _____ Ft. _____ in. _____ in.

9. SAND/GRAVEL PACK: Depth Size Material
 From _____ To _____ Ft. _____
 From _____ To _____ Ft. _____
 From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
<u>0</u>	<u>21</u>	<u>DIRT</u>
<u>21</u>	<u>970</u>	<u>GRANITE</u>
<u>970</u>	<u>972</u>	<u>QUARTZ</u>
<u>972</u>	<u>1005</u>	<u>GRANITE</u>

11. REMARKS:

4 GPM 970 - 972 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price 8-10-06
 SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
 PRINTED NAME OF PERSON CONSTRUCTING THE WELL