



330830

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

060337

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28007

City or Town State Zip Code

(**828**) - **264-2851**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **7/13/2006**

TIME COMPLETED **8:00** AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY **WATAUGA**

DUTCH CREEK RD. OFF HWY 194 OFF BROADST

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other _____
(check appropriate box)

LATITUDE 3 36.10022

LONGITUDE 081.48706

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **205**

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: **80** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **20** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **26**

g. WATER ZONES (depth):

From **178** To **180** From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

Depth Diameter Weight Material

From **0** To **43** Ft. **6 1/8** **.350** **PVC**

From **0** To **0** Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method

From **0** To **20** Ft. **Cement** **Gravity Flow**

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From To Formation Description

0 37 **DIRT**

37 178 **GRANITE**

178 180 **RED GRANITE**

180 205 **GRANITE**

11. REMARKS:

20 GPM 178 - 180 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C. WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price 8-10-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL