332444

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2687

060502

1. WELL CONTRACTOR:

STEVE REECE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply ☐ X

DATE DRILLED 8/30/2006

TIME COMPLETED 2:00 AM ☐ PM ☐ X

3. WELL LOCATION:

CITY: BLOWING ROCK COUNTY WATAUGA

OLD CAMP CATAWBA RD. OFF HWY 321
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 3 36.08785
LONGITUDE 081.39986

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☐ X GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 505

b. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☐ X

c. WATER LEVEL Below Top of Casing: 60 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 2 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 97

g. WATER ZONES (depth):

From 80	To 82	From 240	To 244
From	To	From	To
From	To	From	To

6. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From 0	To 35	Ft.	6 1/8	.350	PVC
From 0	To 0	Ft.			
From	To	Ft.			

7. GROUT:

	Depth		Material	Method
From 0	To 20	Ft.	Cement	Gravity
From	To	Ft.		
From	To	Ft.		

8. SCREEN:

	Depth		Diameter	Slot Size	Material
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From	To	Ft.		
From	To	Ft.		
From	To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	29	DIRT
29	45	GRNAITE
45	55	SANDSTONE
55	80	GRANITE
80	240	GRANITE
240	244	SHALE
244	505	GRANITE

11. REMARKS:

1 GPM 80 - 82 1 GPM 240 - 244
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 9-13-0
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

RECEIVED BY CENTRAL MTN
SEP 20 2006

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05