



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

332446

WELL CONTRACTOR CERTIFICATION # 2687

060364

1. WELL CONTRACTOR:

STEVE REECE
 Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.
 Well Contractor Company Name
 STREET ADDRESS **P. O. BOX 308**
BOONE NC 28607
 City or Town State Zip Code
 (**828**) - **284-2851**
 Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
 STATE WELL PERMIT #(if applicable) _____
 DWQ or OTHER PERMIT #(if applicable) _____
 WELL USE (Check Applicable Box): Residential Water Supply X
 DATE DRILLED **7/29/2006**
 TIME COMPLETED **5:00** AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**
GREER LANE OFF 105 BYPASS
 (Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
 (check appropriate box)

LATITUDE 3 36 26753
 LONGITUDE 081 33847

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 300
 b. DOES WELL REPLACE EXISTING WELL? YES NO X
 c. WATER LEVEL Below Top of Casing: 20 FT.
 (Use "+" if Above Top of Casing)
 d. TOP OF CASING IS 1 FT. Above Land Surface*
 * Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
 e. YIELD (gpm): 4 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 5g

g. WATER ZONES (depth):
 From 60 To 61 From 280 To 283
 From _____ To _____ From _____ To _____
 From _____ To _____ From _____ To _____

6. CASING: Thickness/
 Depth Diameter Weight Material
 From 0 To 32 Ft. 6 1/8 350 PVC
 From 0 To 0 Ft. _____ _____
 From _____ To _____ Ft. _____ _____

7. GROUT: Depth Material Method
 From 0 To 20 Ft. Cement Gravity Flow
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

8. SCREEN: Depth Diameter Slot Size Material
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Depth Size Material
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From	To	Formation Description
0	25	DIRT
25	40	GRANITE
40	60	SHALE
60	61	SHALE
61	280	GRANITE
280	283	QUARTZ
283	300	GRANITE

11. REMARKS:

1 GPM 60 - 61 3 GPM 280 - 283
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 9-13-06
 SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
STEVE REECE
 PRINTED NAME OF PERSON CONSTRUCTING THE WELL