RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

33245

WELL CONTRACTOR CERTIFICATION # 2687

060193

1. WELL CONTRACTOR:

STEVE REECE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐ X
DATE DRILLED 5/25/2006
TIME COMPLETED 9:30 AM ☐ X PM ☐

3. WELL LOCATION:

CITY: BOONE COUNTY WATAUGA

LOT # 39 PRKWY CRSSG OFF R. C. COOK RD. O
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 36.08533
LONGITUDE 081.38300

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☐ X GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 905

b. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☐ X

c. WATER LEVEL Below Top of Casing: 60 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 0.5 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 157

g. WATER ZONES (depth):
From blasted To unknown From To
From To From To
From To From To

6. CASING:

From	To	Depth Ft.	Diameter	Thickness/ Weight	Material
0	34		6 1/8	.350	PVC
0	0				

7. GROUT:

From	To	Depth Ft.	Material	Method
0	20		Cement	Gravity Fl

8. SCREEN:

From	To	Depth Ft.	Diameter in.	Slot Size in.	Material

9. SAND/GRAVEL PACK:

From	To	Depth Ft.	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	28	DIRT
28	80	GRANITE
80	83	SHALE
83	905	GRANITE

11. REMARKS:

0.5 GPM blasted - unknown 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 9-13-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

FILLED BY CENTRAL FILE

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05