



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

332473

WELL CONTRACTOR CERTIFICATION # 2878 060383

I. WELL CONTRACTOR:

STEVE PRICE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2851
Area code - Phone number

WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED 8/8/2006

TIME COMPLETED 11:30 AM X PM

WELL LOCATION:

CITY: **BOONE** COUNTY **WATAUGA**

PAINTED MTN. RD. OFF VANDERPOOL RD. OFF
Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other _____
(check appropriate box)

ALTITUDE 3 38.15058 May be in degrees, minutes, seconds or in a decimal format

LONGITUDE 081.45493

Altitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

f. DISINFECTION: Type HTH Amount 94

g. WATER ZONES (depth):

From 502 To 504 From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING: Thickness/

Depth	Diameter	Weight	Material
From <u>0</u> To <u>82</u> Ft.	<u>6 1/8</u>	<u>350</u>	<u>PVC</u>
From <u>0</u> To <u>0</u> Ft.			
From _____ To _____ Ft.			

7. GROUT: Depth Material Method

From <u>0</u> To <u>20</u> Ft.	<u>Cement</u>	<u>Gravity Flow</u>
From _____ To _____ Ft.		
From _____ To _____ Ft.		

8. SCREEN: Depth Diameter Slot Size Material

From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	

9. SAND/GRAVEL PACK: Depth Size Material

From _____ To _____ Ft.		
From _____ To _____ Ft.		
From _____ To _____ Ft.		

10. DRILLING LOG

From	To	Formation Description
<u>0</u>	<u>54</u>	<u>DIRT</u>
<u>54</u>	<u>502</u>	<u>GRANITE</u>
<u>502</u>	<u>504</u>	<u>QUARTZ</u>
<u>504</u>	<u>525</u>	<u>GRANITE</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

11. REMARKS:

30 GPM 502 - 504 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price 9-15-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,
17 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.