



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

332479

WELL CONTRACTOR CERTIFICATION # 2878

060448

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2851

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 8/17/2006

TIME COMPLETED 3:00 AM PM

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

PRIVATE DR. OFF GARRETT J. AVE. OFF BROOK

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.14073

LONGITUDE 081.38968

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 725

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 30 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 1 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 134

g. WATER ZONES (depth):

From 120 To 121 From 230 To 231

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth Diameter Weight Material

From 0 To 90 Ft. 8 1/8 350 PVC

From 0 To 0 Ft. _____ _____

From _____ To _____ Ft. _____ _____

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From To Formation Description

0 84 DIRT

84 120 GRANITE

120 121 GRANITE

121 230 GRANITE

230 213 GRANITE

231 725 GRANITE

11. REMARKS:

0.5 GPM 120 - 121 0.5 GPM 230 - 231

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price 9-15-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL