



# RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

332481  
060404

WELL CONTRACTOR CERTIFICATION # 2878

### 1. WELL CONTRACTOR:

**STEVE PRICE**

Well Contractor (Individual Name)

**DEWEY WRIGHT WELL & PUMP CO., INC.**

Well Contractor Company Name

STREET ADDRESS P O BOX 308

**BOONE NC 28607**

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

### 2. WELL INFORMATION:

SITE WELL ID #(if applicable) \_\_\_\_\_

STATE WELL PERMIT #(if applicable) \_\_\_\_\_

DWQ or OTHER PERMIT #(if applicable) \_\_\_\_\_

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 8/12/2006

TIME COMPLETED 12:00 AM  PM

### 3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

**PRIVATE RD. OFF HOUND EARS OFF MARION C**

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

### TOPOGRAPHIC / LAND SETTING:

Slope  Valley  Flat  Ridge  Other  
(check appropriate box)

LATITUDE 3 38 10349

LONGITUDE 081 43434

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source:  GPS  Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

### 4. WELL DETAILS:

a. TOTAL DEPTH: 205

b. DOES WELL REPLACE EXISTING WELL? YES  NO

c. WATER LEVEL Below Top of Casing: 60 FT.  
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface\*  
\* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 60 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 30

g. WATER ZONES (depth):

From 170 To 172 From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

6. CASING: Thickness/

Depth Diameter Weight Material

From 0 To 150 Ft. 6 1/8 350 PVC

From 0 To 0 Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

7. GROUT: Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

8. SCREEN: Depth Diameter Slot Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in.

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in.

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in.

9. SAND/GRAVEL PACK: Depth Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 10. DRILLING LOG

From To Formation Description

0 144 DIRT

144 170 GRANITE

170 172 QUARTZ

172 205 GRANITE

### 11. REMARKS:

60 GPM 170 - 172 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price 9-15-06

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

**STEVE PRICE**

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05