



RESIDENTIAL WELL CONSTRUCTION RECORD

332487

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # **2878**

060378

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28607

City or Town State Zip Code

(**828**) - **264-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **8/1/2008**

TIME COMPLETED **8:00** AM PM X

WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

OLD MTN RD OFF ANDY HICKS OFF WORLEY R

Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE **3 36 13149**

May be in degrees, minutes, seconds or in a decimal format

LONGITUDE **081 50582**

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

WELL DETAILS:

TOTAL DEPTH: **200**

DOES WELL REPLACE EXISTING WELL? YES NO X

WATER LEVEL Below Top of Casing: **80** FT.
(Use "+" if Above Top of Casing)

TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

YIELD (gpm): **10** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **25**

g. WATER ZONES (depth):

From **100** To **101** From **100** To **100**

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/
Depth Diameter Weight Material
From **0** To **21** Ft. **6 1/4** **188** **GALV**

From **0** To **0** Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method
From **0** To **20** Ft. **Cement** **Gravity Flow**

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material
From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
0	5	DIRT
5	100	GRANITE
100	101	GRANITE
101	104	GRANITE
104	106	QUARTZ
106	200	GRANITE

11. REMARKS:

1 GPM 100 - 101 9 GPM 104 - 106

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price **9-15-08**
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.