



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

322488

060475

WELL CONTRACTOR CERTIFICATION # 2686

1. WELL CONTRACTOR:

LESLIE REECE
Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name
STREET ADDRESS P O BOX 308
BOONE NC 28607
City or Town State Zip Code
(828) - 284-2851
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
STATE WELL PERMIT #(if applicable) _____
DWQ or OTHER PERMIT #(if applicable) _____
WELL USE (Check Applicable Box): Residential Water Supply X
DATE DRILLED 8/21/2008
TIME COMPLETED 1:00 AM PM X

3. WELL LOCATION:

CITY: BOONE COUNTY: WATAUGA
POPLAR GROVE RD. OFF 105
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3

LONGITUDE _____
Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

May be in degrees, minutes, seconds or in a decimal format

5. WELL DETAILS:

a. TOTAL DEPTH: 180
b. DOES WELL REPLACE EXISTING WELL? YES NO X
c. WATER LEVEL Below Top of Casing: 40 FT.
(Use "+" if Above Top of Casing)
d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
e. YIELD (gpm): 30 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 25
g. WATER ZONES (depth):
From 138 To 139 From _____ To _____
From _____ To _____ From _____ To _____
From _____ To _____ From _____ To _____

6. CASING: Thickness/
Depth Diameter Weight Material
From 0 To 40 Ft. 8 1/8 350 PVC
From 0 To 0 Ft. _____ _____
From _____ To _____ Ft. _____ _____

7. GROUT: Depth Material Method
From 0 To 20 Ft. Cement Gravity Flow
From _____ To _____ Ft. _____ _____
From _____ To _____ Ft. _____ _____

8. SCREEN: Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Size Material
Depth
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

10. DRILLING LOG

From To
0 115
115 138
138 139
139 180

Formation Description:

DIRT SAND
GRANITE
SHALE
GRANITE

11. REMARKS:

30 GPM 138 - 139 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 9-13-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
LESLIE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

REC'D BY CENTRAL FILE
SEP 21 2008 10:55 AM

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.