



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

332495

WELL CONTRACTOR CERTIFICATION # **2686**

050458-2

WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE

NC

28607

City or Town

State

Zip Code

828 - 264-2651

Area code - Phone number

WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

WQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **7/19/2006**

TIME COMPLETED **11:00** AM X PM

WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

JUNALUSKA RD. OFF TATER HILL RD. OFF 421

Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other (check appropriate box)

ELEVATION **3**

LONGITUDE

May be in degrees, minutes, seconds or in a decimal format

Elevation/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

WELL DETAILS:

TOTAL DEPTH: **600**

DOES WELL REPLACE EXISTING WELL? YES NO

WATER LEVEL Below Top of Casing: _____ FT.
(Use "+" if Above Top of Casing)

TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

YIELD (gpm): **0** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount _____

g. WATER ZONES (depth):

From **DRY** To **HOLE** From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING: Thickness/

Depth Diameter Weight Material

From **0** To **68** Ft. **6 1/8** **350** **PVC**

From **0** To **0** Ft. _____

From _____ To _____ Ft. _____

7. GROUT: Depth Material Method

From **0** To **20** Ft. **Cement** **Gravity Flow**

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN: Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Depth Size Material

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From To Formation Description

0 **64** **MUD GRAVEL**

64 **600** **GRANITE**

11. REMARKS:

0 GPM DRY - HOLE 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie W. Reece **8-11-06**

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05