



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2572

7459
10-19

333906

1. WELL CONTRACTOR:

Jody W Mullis
Well Contractor (Individual Name)

Yadkin Well Company Inc.
Well Contractor Company Name

STREET ADDRESS 1908 Hamptonville Road

Hamptonville NC 27020
City or Town State Zip Code

(336) 468-4440
Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) AAI-895

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 10-13-06

TIME COMPLETED 1:00 AM PM

3. WELL LOCATION:

CITY: Boone COUNTY Watson

Water Stone
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 36 15.814

LONGITUDE 81 38.170

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 402'

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 80' FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. YIELD (gpm): 2 1/2 METHOD OF TEST Air pump

f. DISINFECTION: Type HTH Amount 1 1/2 cups

g. WATER ZONES (depth):
From 75' To 82 1/2' From _____ To _____
From 360' To 362 27" From _____ To _____
From _____ To _____ From _____ To _____

6. CASING: Thickness/Weight Material
From 41' Depth To 69' Ft. Diameter 6.25 SDR21 PVC
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

7. GROUT: Depth Material Method
From 0' To 5' Ft. Next-Cement Hand-mixed
From 5' To 30' Ft. Bentonite pumped
From _____ To _____ Ft. _____

8. SCREEN: Depth Diameter Slot Size Material
From _____ To _____ Ft. in. in. _____
From _____ To _____ Ft. in. in. _____
From _____ To _____ Ft. in. in. _____

9. SAND/GRAVEL PACK: Depth Size Material
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

10. DRILLING LOG

From 0' To 402' Formation Description
Soil
med soft granite

RECEIVED
DIV OF WATER QUALITY
OCT 23 2006

Bit Serial No. _____ Size off 6.100

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Jody W Mullis 10-13-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Jody W Mullis
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05

Date site visited 9-22-06 by UP Permit required: Yes No