334712

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2686

060280-1

1. WELL CONTRACTOR:

LESLIE REECE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐X
DATE DRILLED 7/10/2006
TIME COMPLETED 11:00 AM ☐X PM ☐

3. WELL LOCATION:

CITY: BOONE COUNTY WATAUGA

LOT # 38 IN CABIN COVE OFF BLACK ROCK OFF
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

May be in degrees, minutes, seconds or in a decimal format

LATITUDE 3 36.14461
LONGITUDE 081.42159

Latitude/longitude source: ☐X GPS ☐ Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 750

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☐X

c. **WATER LEVEL** Below Top of Casing: _____ FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. **YIELD (gpm):** 0 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount**

g. **WATER ZONES** (depth):
From DRY To HOLE From To
From To From To
From To From To

6. CASING:

	Depth	Diameter	Thickness/ Weight	Material
From 0 To 84 Ft.		6 1/4	.188	GALV
From 0 To 0 Ft.				
From To Ft.				

7. GROUT:

	Depth	Material	Method
From 0 To 20 Ft.		Cement	Gravity Flow
From To Ft.			
From To Ft.			

8. SCREEN:

	Depth	Diameter	Slot Size	Material
From To	Ft.	in.	in.	
From To	Ft.	in.	in.	
From To	Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth	Size	Material
From To	Ft.		
From To	Ft.		
From To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	80	MUD GRAVEL
80	750	GRANITE

RECEIVED
DIV. OF WATER QUALITY
NOV 16 2006

11. REMARKS:

0 GPM DRY - HOLE 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 11-10-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05