



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

334716

060541

WELL CONTRACTOR CERTIFICATION # 2687

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE

NC

28607

City or Town

State

Zip Code

(**828**) - **264-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply **X**

DATE DRILLED **9/11/2006**

TIME COMPLETED **5:00** AM PM

3. WELL LOCATION:

CITY: **BOONE**

COUNTY: **WATAUGA**

LONG HOPE RD. OFF LITTLE CREEK OFF MEAT

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other _____
(check appropriate box)

LATITUDE 3

LONGITUDE _____

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **505**

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: **100** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **5** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **85**

g. WATER ZONES (depth):

From **480** To **482** From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

From _____ To **21** Ft. Diameter **6 1/4** Weight **.188** Material **GALV**

From **0** To **0** Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

From **0** To **20** Ft. Material **Cement** Method **Gravity Flow**

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

From _____ To _____ Ft. _____ in. _____ in. Material _____

From _____ To _____ Ft. _____ in. _____ in. Material _____

From _____ To _____ Ft. _____ in. _____ in. Material _____

9. SAND/GRAVEL PACK:

Depth _____ Size _____ Material _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
0	5	DIRT
5	115	GRANITE
115	117	QUARTZ
117	480	GRANITE
480	482	QUARTZ
482	505	GRANITE

RECEIVED
DIV. OF WATER QUALITY
NOV 16 2006

11. REMARKS:

5 GPM 480 - 482 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece **11-9-06**
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,
1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05