



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2687

334729

060469-1

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28607

City or Town State Zip Code

(**828**) - **264-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **10/12/2006**

TIME COMPLETED **3:00** AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

BIG HILL RD. OFF 184 OFF 421

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other _____
(check appropriate box)

LATITUDE 3 **36.17022**

LONGITUDE 081.37377

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **600**

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: **5** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **0.25** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **119**

g. WATER ZONES (depth):

From **80** To **83** From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth	Diameter	Weight	Material
From 0 To 72 Ft.	6 1/4	188	GALV
From 0 To 0 Ft.			
From _____ To _____ Ft.			

7. GROUT:

Depth	Material	Method
From 0 To 20 Ft.	Cement	Gravity Flow
From _____ To _____ Ft.		
From _____ To _____ Ft.		

8. SCREEN:

Depth	Diameter	Slot Size	Material
From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	

9. SAND/GRAVEL PACK:

Depth	Size	Material
From _____ To _____ Ft.		
From _____ To _____ Ft.		
From _____ To _____ Ft.		

10. DRILLING LOG

From	To	Formation Description
0	65	DIRT
65	80	GRANITE
80	83	SHALE
83	870	GRANITE

RECEIVED
DIV. OF WATER QUALITY
NOV 16 2006

11. REMARKS:

0.25 GPM 80 - 83 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece **11-9-06**
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05