



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

334721

WELL CONTRACTOR CERTIFICATION # 2687

050469-2

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 10/13/2006

TIME COMPLETED 3 AM PM

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

BIG HILL RD. OFF HWY 194 OFF HWY 421

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other _____
(check appropriate box)

LATITUDE 3 36 17022

LONGITUDE 081 37377

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 300

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 30 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 3 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 55

g. WATER ZONES (depth):

From 55 To 56 From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

Depth Diameter Weight Material

From 0 To 54 Ft. 6 1/8 350 PVC

From 0 To 0 Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method

From 0 To 21 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From To Formation Description

0 48 DIRT

48 55 GRANITE

55 56 SHALE

56 240 GRANITE

240 244 QUARTZ

244 300 GRANITE

11. REMARKS:

3 GPM 55 - 56 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 11-9-06

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL