



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2687

060588

354731

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28607

City or Town State Zip Code

(**828**) - **264-2851**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **10/4/2006**

TIME COMPLETED **11:00** AM X PM

3. WELL LOCATION:

CITY: **BLOWING ROCK** COUNTY **WATAUGA**

SAMPSON RD. OFF PARKWAY OFF AHO RD. OF

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 **36.08712**

LONGITUDE **081.35501**

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **400**

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: **30** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **0.5** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **73**

g. WATER ZONES (depth):

From **90** To **93** From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

Depth Diameter Weight Material

From **0** To **34** Ft. **6 1/8** **350** **PVC**

From **0** To **0** Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method

From **0** To **20** Ft. **Cement** **Gravity Flow**

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From To Formation Description

0 **28** **DIRT**

28 **90** **GRANITE**

90 **93** **SHALE**

93 **400** **GRANITE**

RECEIVED
DIV. OF WATER QUALITY
NOV 16 2006

11. REMARKS:

0.5 GPM 90 - 93 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

Steve Reece **11-9-06**
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL