



# RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2687

060417

334793

### 1. WELL CONTRACTOR:

**STEVE REECE**

Well Contractor (Individual Name)

**DEWEY WRIGHT WELL & PUMP CO., INC.**

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

**BOONE NC 28607**

City or Town State Zip Code

(**828**) - **264-2651**

Area code - Phone number

### 2. WELL INFORMATION:

SITE WELL ID #(if applicable) \_\_\_\_\_

STATE WELL PERMIT #(if applicable) \_\_\_\_\_

DWQ or OTHER PERMIT #(if applicable) \_\_\_\_\_

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 9/26/2006

TIME COMPLETED 11:00 AM  XPM

### 3. WELL LOCATION:

CITY: **BOONE** COUNTY **WATAUGA**

**OLD HARTLEY RD. OFF DEWITT BARNETT RD. 0**

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

### TOPOGRAPHIC / LAND SETTING:

Slope  Valley  Flat  Ridge  Other \_\_\_\_\_  
(check appropriate box)

LATITUDE 3 **36.12310**

LONGITUDE 081.45958

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source:  GPS  Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

### 5. WELL DETAILS:

a. TOTAL DEPTH: 405

b. DOES WELL REPLACE EXISTING WELL? YES  NO

c. WATER LEVEL Below Top of Casing: 40 FT.  
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface\*  
\* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 1.5 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 73

### g. WATER ZONES (depth):

From 70 To 73 From 376 373

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

### 6. CASING:

Depth Diameter Weight Material Thickness/

From 0 To 42 Ft. 6 1/4 .188 GALV

From 0 To 0 Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 8. SCREEN:

Depth Diameter Slot Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

### 9. SAND/GRAVEL PACK:

Depth Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 10. DRILLING LOG

From To Formation Description

0 30 DIRT ROCK

30 50 GRANITE

50 53 SHALE

53 70 GRANITE

70 73 SHALE

73 370 GRANITE

370 373 QUARTZ

373 405 GRANITE

RECEIVED  
DIV. OF WATER QUALITY  
NOV 16 2006

### 11. REMARKS:

0.5 GPM 70 - 73 1 GPM 370 - 373

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 11-9-06  
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE  
PRINTED NAME OF PERSON CONSTRUCTING THE WELL