RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878 060711

335948

1. WELL CONTRACTOR:

STEVE PRICE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P O BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐ X
DATE DRILLED 11/28/2006
TIME COMPLETED 11:00 AM ☐ X PM ☐

3. WELL LOCATION:

CITY: BOONE COUNTY WATAUGA

RIVERMILL OFF ROMINGER RD. OFF 321 OFF 42
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 3 38.14502
LONGITUDE 081.49483

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☐ GPS X ☐ Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 820

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☐ X

c. **WATER LEVEL** Below Top of Casing: 300 FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. **YIELD (gpm):** 30 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount** 108

g. **WATER ZONES** (depth):

From	To	From	To
660	661	692	693
730	731		

6. CASING:

From	To	Depth	Diameter	Thickness/ Weight	Material
0	23	Ft.	6 1/8	350	PVC
0	0	Ft.			

7. GROUT:

From	To	Depth	Material	Method
0	20	Ft.	Cement	Gravity Flow

8. SCREEN:

From	To	Depth	Diameter	Slot Size	Material
		Ft.	in.	in.	

9. SAND/GRAVEL PACK:

From	To	Depth	Size	Material
		Ft.		

10. DRILLING LOG

From	To	Formation Description
0	17	DIRT
17	660	GRANITE
660	661	QUARTZ
661	692	GRANITE
692	693	QUARTZ
693	730	GRANITE
730	731	QUARTZ RED GRANIT
731	820	GRANITE

RECEIVED
DIV. OF WATER QUALITY
DEC 14 2006

11. REMARKS:

2 GPM 660 - 661 2 GPM 692 - 693
26 GPM 730 - 731 .0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price 12-6-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05