



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

060295

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(**828**) - **284-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED 11/7/2006

TIME COMPLETED 11:30 AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

LOT # 1 B GOLDEN RIDGE OFF FLAT TOP RD. 0

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 38.10021

LONGITUDE 081.40047

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 305

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: 20 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 12 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 57

g. WATER ZONES (depth):

From 100 To 101 From 256 To 253

From 290 To 291 From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth Diameter Weight Material

From 0 To 30 Ft. 6 1/8 .350 PVC

From 0 To 0 Ft. _____ _____

From _____ To _____ Ft. _____ _____

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From To Formation Description

0 24 DIRT

24 100 GRANITE

100 101 QUARTZ

101 252 GRANITE

252 253 QUARTZ

253 290 GRANITE

290 291 QUARTZ

291 305 GRANITE

335974

RECEIVED
DIV. OF WATER QUALITY
DEC 14 2006

11. REMARKS:

2 GPM 100 - 101 1 GPM 252 - 253

9 GPM 290 - 291 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL