



# RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2687

060630

### 1. WELL CONTRACTOR:

**STEVE REECE**

Well Contractor (Individual Name)

**DEWEY WRIGHT WELL & PUMP CO., INC.**

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

**BOONE**

**NC**

**28607**

City or Town

State

Zip Code

(**828**) - **264-2651**

Area code - Phone number

### 2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply  X

DATE DRILLED **11/22/2006**

TIME COMPLETED **1:00** AM  PM  X

### 3. WELL LOCATION:

CITY: **BOONE**

COUNTY

**WATAUGA**

**HWY 421**

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

### TOPOGRAPHIC / LAND SETTING:

Slope  Valley  Flat  Ridge  Other  
(check appropriate box)

LATITUDE 3 **38 14048**

LONGITUDE **081 43985**

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source:  GPS  Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

### 5. WELL DETAILS:

a. TOTAL DEPTH: **305**

b. DOES WELL REPLACE EXISTING WELL? YES  NO  X

c. WATER LEVEL Below Top of Casing: **60** FT.  
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface\*  
\* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **15** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **49**

g. WATER ZONES (depth):

From **130** To **133** From **240** To **244**

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

### 6. CASING:

Thickness/

Depth Diameter Weight Material

From **0** To **12** Ft. **6 1/8** **350** **PVC**

From **0** To **0** Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 7. GROUT:

Depth Material Method

From **0** To **20** Ft. **Cement** **Gravity Flow**

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 8. SCREEN:

Depth Diameter Slot Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

### 9. SAND/GRAVEL PACK:

Depth Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 10. DRILLING LOG

From To Formation Description

**0** **115** **DIRT**

**115** **130** **GRANITE**

**130** **133** **SHALE**

**133** **240** **GRANITE**

**240** **244** **QUARTZ**

**244** **305** **GRANITE**

RECEIVED  
DIV. OF WATER QUALITY

DEC 14 2006

### 11. REMARKS:

**5 GPM 130 - 133 10 GPM 240 - 244**

**0 GPM - 0 GPM -**

**0 GPM - 0 GPM -**

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

*Steve Reece* **12-9-06**  
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

**STEVE REECE**  
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05

336013