



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2687

060451

336023

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28607

City or Town State Zip Code

(**828**) - **264-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **10/28/2006**

TIME COMPLETED **6:30** AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY **WATAUGA**

FOREST GROVE RD. OFF BETHEL RD. OFF 321

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 **38.18159**

LONGITUDE 081.48384

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 125

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: 20 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 20 METHOD OF TEST Air

f. DISINFECTION: Type **HTH** Amount 22

g. WATER ZONES (depth):

From 0 To 63 From 90 To 93

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

From 0 To 41 Ft. Diameter **6 1/8** Weight **.350** Material **PVC**

From 0 To 0 Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

From 0 To 20 Ft. Material **Cement** Method **Gravity Flow**

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

From _____ To _____ Ft. _____ in. _____ in. Material _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

From _____ To _____ Ft. _____ Size _____ Material _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
0	35	DIRT ROCK
35	48	GRANITE
48	80	GRANITE SHALE
80	83	SHALE
83	90	GRANITE
90	93	SHALE
93	125	GRANITE

RECEIVED
DIV OF WATER QUALITY
DEC 14 2006

11. REMARKS:

10 GPM 60 - 63 10 GPM 90 - 93
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 12-9-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05