RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

337657

050643

WELL CONTRACTOR CERTIFICATION # 2688

1. WELL CONTRACTOR:

LESLIE REECE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2051
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐ X
DATE DRILLED 12/19/2006
TIME COMPLETED 10:00 AM ☐ X PM ☐

3. WELL LOCATION:

CITY: BOONE COUNTY WATAUGA

LOT # 24 HAMPTON FARM OFF BAMBOO RD. OF
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 3 38.12137
LONGITUDE 081.37663

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☐ GPS ☐ Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 800

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☐ X

c. **WATER LEVEL** Below Top of Casing: 200 FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. **YIELD (gpm):** 7.5 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount** 120

g. **WATER ZONES** (depth):
From 575 To 676 From To
From To From To
From To From To

6. CASING:

	Depth	Diameter	Thickness/ Weight	Material
From	0 To 58 Ft.	6 1/8	350	PVC
From	0 To 0 Ft.			
From	To Ft.			

7. GROUT:

	Depth	Material	Method
From	0 To 20 Ft.	Cement	Gravity Flow
From	To Ft.		
From	To Ft.		

8. SCREEN:

	Depth	Diameter	Slot Size	Material
From	To Ft.	in.	in.	
From	To Ft.	in.	in.	
From	To Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth	Size	Material
From	To Ft.		
From	To Ft.		
From	To Ft.		

10. DRILLING LOG

From	To	Formation Description
0	54	DIRT
54	675	GRANITE
675	676	QUARTZ
676	800	GRANITE

RECEIVED
DIV. OF WATER QUALITY
JAN 29 2007

11. REMARKS:

7.5 GPM 675 - 676 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 1-24-07
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05