



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

337659

WELL CONTRACTOR CERTIFICATION # 2886

060745

1. WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE

NC

28807

City or Town

State

Zip Code

(**828**) - **284-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED **11/30/2006**

TIME COMPLETED **4:00** AM PM

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

JAKES MTN RD. OFF LITTLE LAUREL RD. OFF B

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.00773

LONGITUDE 081.36.823

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **1000**

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: **100** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **6** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **135**

g. WATER ZONES (depth):

From **219** To **219** From **746** To **747**

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth	Diameter	Weight	Material
From 0 To 60 Ft.	6 1/8	350	PVC
From 0 To 0 Ft.			
From _____ To _____ Ft.			

7. GROUT:

Depth	Material	Method
From 0 To 20 Ft.	Cement	Gravity Flow
From _____ To _____ Ft.		
From _____ To _____ Ft.		

8. SCREEN:

Depth	Diameter	Slot Size	Material
From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	

9. SAND/GRAVEL PACK:

Depth	Size	Material
From _____ To _____ Ft.		
From _____ To _____ Ft.		
From _____ To _____ Ft.		

10. DRILLING LOG

From	To	Formation Description
0	58	DIRT
58	218	GRANITE
218	219	SHALE
219	746	GRANITE
746	747	QUARTZ
74	1000	GRANITE

RECEIVED
DIV. OF WATER QUALITY

JAN 29 2007

11. REMARKS:

4 GPM 218 - 219 2 GPM 746 - 747
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reea **1-24-07**
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,
1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05