



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

337671
060767

WELL CONTRACTOR CERTIFICATION # 2687

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(**828**) - **264-2851**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 1/4/2007

TIME COMPLETED 3:00 AM PM

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

OLD 421 OFF 421

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 38.13443

LONGITUDE 081.34808

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 400

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 1 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 4 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 78

g. WATER ZONES (depth):

From 0 To 00 From 300 To 303

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

Depth Diameter Weight Material

From 0 To 80 Ft. 6 1/4 188 GALV

From 0 To 0 Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
0	83	DIRT ROCK GRAVEL
83	95	GRANITE SANDSTOMI
95	99	SANDSTONE
99	110	GRANITE
110	120	SANDSTONE
120	380	GRANITE
380	383	QUARTZ
383	410	GRANITE

RECEIVED
DIV. OF WATER QUALITY

JAN 29 2007

11. REMARKS:

2 GPM 95 - 99 2 GPM 360 - 363

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 1-23-07
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL