



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

337672

WELL CONTRACTOR CERTIFICATION # 2687

060760

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE

NC

28607

City or Town

State

Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 1/11/2007

TIME COMPLETED 4:30 AM PM

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

LOT # 24 RIVERS EDGE OFF TWIN RIVERS DR.

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.09745

LONGITUDE 081.45283

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 905

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 500 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 5 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 85

g. WATER ZONES (depth):

From 850 To 853 From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

Depth Diameter Weight Material

From 0 To 22 Ft. 6 1/8 350 PVC

From 0 To 0 Ft. _____ _____

From _____ To _____ Ft. _____ _____

7. GROUT:

Depth

Material

Method

From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

8. SCREEN:

Depth

Diameter

Slot Size

Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth

Size

Material

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From To Formation Description

0 1

DIPT

1 850

GRANITE

850 853

QUARTZ

853 905

GRANITE

RECEIVED
DIV. OF WATER QUALITY

JAN 29 2007

11. REMARKS:

5 GPM 850 - 853 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 1-23-07
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL