



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2791

RECEIVED
N.C. Dept. of ENR
MAY 07 2007
Winston-Salem
Regional Office
060754

1. WELL CONTRACTOR:

ALBERT SLATE
Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name
STREET ADDRESS P. O. BOX 308
BOONE NC 28607
City or Town State Zip Code
(828) - 264-2851
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
STATE WELL PERMIT #(if applicable) _____
DWQ or OTHER PERMIT #(if applicable) _____
WELL USE (Check Applicable Box): Residential Water Supply
DATE DRILLED 1/11/2007
TIME COMPLETED 8:00 AM PM

3. WELL LOCATION:

CITY: BOONE COUNTY: WATAUGA
ALEX WELBORN RD. OFF DICK WATSON OFF O
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other _____
(check appropriate box)

LATITUDE 3 38.14084
LONGITUDE _____ 081.31413

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 300
b. DOES WELL REPLACE EXISTING WELL? YES NO
c. WATER LEVEL Below Top of Casing: 30 FT.
(Use "+" if Above Top of Casing)
d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
e. YIELD (gpm): 2 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 55

g. WATER ZONES (depth):
From UNKNOWN To _____ From _____ To _____
From _____ To _____ From _____ To _____
From _____ To _____ From _____ To _____

6. CASING: Thickness/
Depth Diameter Weight Material
From 0 To 82 Ft. 6 1/4 .188 GALV
From 0 To 0 Ft. _____
From _____ To _____ Ft. _____

7. GROUT: Depth Material Method
From 0 To 20 Ft. Cement Gravity Flow
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

8. SCREEN: Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Depth Size Material
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

10. DRILLING LOG

From To Formation Description
0 75 DIRT SAND GRAVEL
75 300 GRANITE QUARTZ

11. REMARKS:

2 GPM UNKNOWN - 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Albert Slate 3-1-07
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

ALBERT SLATE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

RECEIVED
DIV. OF WATER QUALITY
MAR 13 2007