



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

341544

WELL CONTRACTOR CERTIFICATION # 2878

070118

1. WELL CONTRACTOR:

STEVE PRICE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE **NC** **28607**
City or Town State Zip Code

(**828**) - **284-2651**
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) W95-0110

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 4/12/2007

TIME COMPLETED 04:00 AM PM

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

WINKLERS CREEK RD. OFF WILSON ROAD OFF
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 38.10975

LONGITUDE 081.41391

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 300

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 40 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 8 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 54

g. WATER ZONES (depth):

From 243 To 244 From 288 To 287

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth	Diameter	Weight	Material
From <u>0</u> To <u>105</u> Ft.	<u>6 1/8</u>	<u>350</u>	<u>PVC</u>
From <u>0</u> To <u>0</u> Ft.			
From _____ To _____ Ft.			

7. GROUT:

Depth	Material	Method
From <u>0</u> To <u>20</u> Ft.	<u>Cement</u>	<u>Gravity Flow</u>
From _____ To _____ Ft.		
From _____ To _____ Ft.		

8. SCREEN:

Depth	Diameter	Slot Size	Material
From _____ To _____ Ft.	_____ in.	_____ in.	_____
From _____ To _____ Ft.	_____ in.	_____ in.	_____
From _____ To _____ Ft.	_____ in.	_____ in.	_____

9. SAND/GRAVEL PACK:

Depth	Size	Material
From _____ To _____ Ft.		
From _____ To _____ Ft.		
From _____ To _____ Ft.		

10. DRILLING LOG

From	To	Formation Description
<u>0</u>	<u>99</u>	<u>DIRT, MUD, BOULDER</u>
<u>99</u>	<u>243</u>	<u>GRANITE</u>
<u>243</u>	<u>244</u>	<u>QUARTS</u>
<u>244</u>	<u>288</u>	<u>GRANITE</u>
<u>288</u>	<u>287</u>	<u>QUARTS</u>
<u>287</u>	<u>300</u>	<u>GRANITE</u>

DIV OF WATER QUALITY

MAY 18 2007

RECEIVED
N.C. Dept. of ENR

JUL 02 2007

11. REMARKS:

2 GPM 243 - 244 8 GPM 288 - 287

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C. WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price 5-4-07
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL