



# RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

345228

WELL CONTRACTOR CERTIFICATION # **2681**

070217

### 1. WELL CONTRACTOR:

**STEVE PETTY**

Well Contractor (Individual Name)

**DEWEY WRIGHT WELL & PUMP CO., INC.**

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

**BOONE NC 28607**

City or Town State Zip Code

( **828** ) - **264-2651**

Area code - Phone number

### 2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable) **W95-0075**

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED **6/18/2007**

TIME COMPLETED **05:30** AM  PM

### 3. WELL LOCATION:

CITY: **BOONE** COUNTY: **WATAUGA**

**ISAACS HOME OFF HWY 421**

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

### TOPOGRAPHIC / LAND SETTING:

Slope  Valley  Flat  Ridge  Other  
(check appropriate box)

LATITUDE **3 36.15939**

LONGITUDE **081.45826**

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source:  GPS  Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

### 5. WELL DETAILS:

a. TOTAL DEPTH: **705**

b. DOES WELL REPLACE EXISTING WELL? YES  NO

c. WATER LEVEL Below Top of Casing: **200** FT.  
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface\*  
\* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **15** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **106**

g. WATER ZONES (depth):

From **180** To **182** From **685** To **687**

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

### 6. CASING:

Depth Diameter Weight Material

From **0** To **42** Ft. **6 1/4** **188** **GALV**

From **0** To **0** Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 7. GROUT:

Depth Material Method

From **0** To **20** Ft. **Cement** **Gravity Flow**

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 8. SCREEN:

Depth Diameter Slot Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_

### 9. SAND/GRAVEL PACK:

Depth Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 10. DRILLING LOG

From To Formation Description

**0 15 DIRT**

**15 180 GRANITE**

**180 182 SHALE**

**182 685 GRANITE**

**685 687 GRANITE**

**687 705 GRANITE**

### 11. REMARKS:

**1 GPM 180 - 182 14 GPM 685 - 687**

**0 GPM - 0 GPM -**

**0 GPM - 0 GPM -**

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

*Steve Petty*

SIGNATURE OF CERTIFIED WELL CONTRACTOR

**7-14-07**

DATE

**STEVE PETTY**

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05