



# RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

ARW

323285

WELL CONTRACTOR CERTIFICATION # 2686

050703-3

### 1. WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO. INC

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607  
City or Town State Zip Code

(828) - 204-2051  
Area code - Phone number

### 2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 1/16/2005

TIME COMPLETED 3:30 AM  PM

### 3. WELL LOCATION:

CITY: BANNER ELK COUNTY: AVERY

LOT #7 TWIN PONDS OFF ROCKY PARKWAY OFF  
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

### TOPOGRAPHIC / LAND SETTING:

Slope  Valley  Flat  Ridge  Other  
(check appropriate box)

LATITUDE 3

LONGITUDE

Latitude/longitude source:  GPS  Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

May be in degrees, minutes, seconds or in a decimal format

### 5. WELL DETAILS:

a. TOTAL DEPTH: 300

b. DOES WELL REPLACE EXISTING WELL? YES  NO

c. WATER LEVEL Below Top of Casing: 100 FT.  
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface\*  
\* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 12 METHOD OF TEST Air

f. DISINFECTION: Type HTW Amount 31

g. WATER ZONES (depth):

From 223 To 224 From To

From To From To

From To From To

### 6. CASING:

Depth Diameter Weight Material  
From 0 To 21 Ft. 8 1/8 350 PVC

From 0 To 0 Ft. Material

From To Ft. Material

### 7. GROUT:

Depth Material Method  
From 0 To 20 Ft. Cement Gravity Flow

From To Ft. Method

From To Ft. Method

### 8. SCREEN:

Depth Diameter Slot Size Material  
From To Ft. in. in.

From To Ft. in. in.

From To Ft. in. in.

### 9. SAND/GRAVEL PACK:

Depth Size Material  
From To Ft. Material

From To Ft. Material

From To Ft. Material

### 10. DRILLING LOG

From	To	Formation Description
0	2	DIRT
2	223	GRANITE
223	224	SHALE
224	300	GRANITE

RECEIVED

Asheville Regional Office  
Aquifer Protection

### 11. REMARKS:

12 GPM 223 - 224 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 2-21-06  
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE  
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a  
Rev. 7/05