



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

abd

323236

WELL CONTRACTOR CERTIFICATION # 2686

050703 2

1. WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC

Well Contractor Company Name

STREET ADDRESS P O BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 1/18/2008

TIME COMPLETED 4:00 AM PM

3. WELL LOCATION:

CITY: IVERSFIELD COUNTY: AVERY

LOT #8 TWIN PONDS OFF ROCKY PARKWAY OFF
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3

LONGITUDE

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 300

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 100 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 50 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 11

g. WATER ZONES (depth):

From 285 To 287 From To

From To From To

From To From To

6. CASING:

Depth Diameter Weight Material

From 0 To 21 Ft. 8 1/8 350 PVC

From 0 To 0 Ft. Material

From To Ft. Material

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From To Ft. Method

From To Ft. Method

8. SCREEN:

Depth Diameter Slot Size Material

From To Ft. in. in.

From To Ft. in. in.

From To Ft. in. in.

9. SAND/GRAVEL PACK:

Depth Size Material

From To Ft. Material

From To Ft. Material

From To Ft. Material

10. DRILLING LOG

From	To	Formation Description
0	2	DIRT
2	285	GRANITE
285	287	SHALE
287	300	GRANITE

RECEIVED

Asheville Regional Office
Aquifer Protection

50 GPM 285 - 287 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 2-21-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL