



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # **2878**

060567

335978

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28807

City or Town State Zip Code

(**828**) - **264-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ OR OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **11/2/2008**

TIME COMPLETED **8:00** AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **AVERY**

APPLE HILL OFF BLADEN RD. OFF OLIVER HILL

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE **3** **36.11753**

LONGITUDE **081.48970**

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **605**

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: **100** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C.0118

e. YIELD (gpm): **20** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **108**

g. WATER ZONES (depth):
From **518** to **517** From **538** to **531**
From **575** to **578** From _____ to _____
From _____ to _____ From _____ to _____

6. CASING:
Depth Diameter Weight Material
From **0** to **24** Ft. **6 1/8** **.350** **PVC**
From **0** to **0** Ft. _____ _____ _____
From _____ to _____ Ft. _____ _____ _____

7. GROUT: Depth Material Method
From **0** to **20** Ft. **Cement** **Gravity Flow**
From _____ to _____ Ft. _____ _____
From _____ to _____ Ft. _____ _____

8. SCREEN: Depth Diameter Slot Size Material
From _____ to _____ Ft. _____ in. _____ in. _____
From _____ to _____ Ft. _____ in. _____ in. _____
From _____ to _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:
Depth Size Material
From _____ to _____ Ft. _____ _____
From _____ to _____ Ft. _____ _____
From _____ to _____ Ft. _____ _____

10. DRILLING LOG

From	To	Formation Description
0	18	DIRT
18	518	GRANITE
518	517	GRANITE QUARTZ
517	530	GRANITE
530	531	QUARTZ
531	575	GRANITE
575	578	QUARTZ
578	605	GRANITE

RECEIVED
DIV. OF WATER QUALITY

DEC 14 2008

11. REMARKS:

0.5 GPM 518 - 517 **0.5 GPM 530 - 531**
19 GPM 575 - 578 **0 GPM -**
0 GPM - **0 GPM -**

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price
SIGNATURE OF CERTIFIED WELL CONTRACTOR **12-6-08** DATE

STEVE PRICE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,
1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.